



Colorado Mountain College

Voice and Data Install

Invitation to Bid

Number #373-07

Due: March 1, 2007

At close of business

Addendum

#1

Dated 02/15/07

Addendum for Rifle cabling

1. Use Plenum for all voice and data cables.
2. The ceilings will be drop ceilings.
3. Please use 2 post racks for patch panels.
4. Please pull 2 data and 1 voice to all locations indicated with ½ shaded triangles.
5. The MDF will be the Server Room #126.
6. The IDF will be the Electrical Room #149. Please pull 6 strand multi-mode fiber with ST connectors and 5 CAT6E cables between rooms 149 and 126.
7. Please use RG 6 coaxial Quad shield for TV.
8. Contractor will provide bridle rings for cables in the ceiling.